



# Danville Fire Department

## Framing Pre-Inspection Checklist

This worksheet is intended to assist the contractor in understanding specific expectations during the inspection process. DFD will keep this document as a part of the permanent project file and will use it to verify code compliance. The applicant (**Owner/ Occupant**) needs to sign and date this document and is responsible for assuring the accuracy and consistency of the information provided herein. **Please submit this checklist prior to calling for the inspection. You may send it via e-mail (preferred) to [fireprevention@danvilleindiana.org](mailto:fireprevention@danvilleindiana.org) or via FAX to 317-745-3022**

### PROPERTY INFORMATION

Project Name:

Project Address:

Owner's Name:

Owner's Address:

Phone #:

Fax #:

Email:

### CONTRACTOR

Company Name:

Company Address:

Contact Name (Designer):

Phone #:

Fax #:

Email:

### BASIC INFORMATION

Yes  No

1. Are there any fire-resistive rated walls and/or floor ceiling assemblies?  
If **yes**, proceed to Question 2 thru 26.  
If **no**, Answer Questions 4 thru 26.

Yes  No  N/A

2. Are copies of all required UL fire-stop systems to be installed in **rated wall locations** (*after framing inspection and prior to final inspection*) available on site for review by fire inspector?

Yes  No  N/A

3. Will there be an "independent" fire stop contractor/installer used?

Yes  No  N/A

4. Have you verified that "fireblocking" has been installed in **wood framed construction** at 10 foot intervals, per IBC 717.2.2?

Yes  No  N/A

5. Have you verified that fire resistive rated caulk has been installed in the penetrations of the "fireblock" noted in Question 4 per IBC 717.2.2? (**Please note that caulking must be certified for use in commercial applications**)?

Yes  No  N/A

6. All wall cavities shall be free of insulating materials at the time of inspection, please confirm.

Yes  No  N/A

7. Location of Exit Signs per approved plans (*and/or per fire inspector*) IBC 1011.1?

Yes  No  N/A

8. Emergency Lighting per approved plans (*and/or per fire inspector*) IBC 1006.1 & 1006.3 (*including exit discharge*)?

Yes  No  N/A

9. Attic Access dimension (minimum 20 X 40 inch) head space (minimum 30 inch) and location per IBC 1209.2?

Yes  No  N/A

10. Fire Alarm Device (**horns/strobes/pull stations**) locations per approved plans (*and/or per fire inspector*) per NFPA 72:7.5.4(2002 Edition)?

Yes  No  N/A

11. Fire Detection Device (i.e. **smoke and/or heat detectors**) per approved plans (*and/or per fire inspector*) IBC 907?

**DRAFTSTOPPING (General)**

Yes  No  N/A

12. Draft Stopping Materials shall not be less than 0.5-inch gypsum board, or 0.375-inch wood structural panel, or 0.375-inch particleboard per IBC 717.3.1?

Yes  No  N/A

13. Penetrations and Openings shall be sealed with fire rated caulking to maintain the integrity of draft stops per IBC 717.3.1?

**DRAFTSTOPPING (Attics and Roof Spaces)**

Yes  No  N/A

14. A permanently marked weatherproof metal or rigid plastic sign secured with corrosion resistant wire, chain, or other approved provided?

Yes  No  N/A

15. **Non-Sprinklered Group R-1 & R-2 Occupancies-** Draft Stopping installed above and in line with Unit Separation Walls per IBC 717.4.2?

Yes  No  N/A

16. **Non-Sprinklered in All Occupancies except Group R-1 & R-2-** Draft Stopping to divide up to less than 3,000 s.f. areas, per IBC 717.4.3?

Yes  No  N/A

17. **Sprinklered Group R-1 & R-2 Occupancies-**Draft Stopping Not Required-when sprinklers provided in combustible concealed spaces per IBC 717.4.2?

Yes  No  N/A

18. **Sprinklered in All Occupancies except Group R-1 & R-2-** Draft Stopping not required with **NFPA 13** Sprinkler Systems per IBC 717.4.3?

**DRAFTSTOPPING (Floors)**

Yes  No  N/A

19. **Non-Sprinklered Group R-1, R-2, R-3 & R-4 Occupancies –** Draft Stopping installed above and in line with Unit Separation Walls, per IBC 717.3.2?

Yes  No  N/A

20. **Non-Sprinklered in All Occupancies except Group R-1, R-2, R-3 & R-4-** Draft Stopping to divide up in to less than 1,000 s.f. areas, per IBC 717.3.3?

Yes  No  N/A

21. **Sprinklered Group R-1, R-2, R-3 & R-4 Occupancies-** Draft Stopping Not Required-when sprinklers provided in combustible concealed spaces, per IBC 717.3.2?

Yes  No  N/A

22. **Sprinklered in All Occupancies except Group R-1, R-2, R-3 & R-4-** Draft Stopping not required with **NFPA 13** Sprinkler Systems per IBC 717.3.3?

**KITCHEN HOOD SYSTEM**

Yes  No  N/A

23. Is the wall immediately adjacent to Kitchen Appliance constructed with non-combustible framing per IMC 507.9?

Yes  No  N/A

24. Please note that detailed information for Kitchen Hood Systems much be completed with **Kitchen Hood Pre-Inspection Checklist.**

**DOCUMENTATION REQUIRED AT FINAL**

Yes  No  N/A

25. Contractor's Material and Test Certificate for Aboveground Piping

Yes  No  N/A

26. Pipe Sizes less than 3 inches in diameter must be protected with intumescent fire-resistive caulking materials.

**Owner or General Contractor**

I certify that the information provided in this document is true and accurate.

\_\_\_\_\_  
(Project Name or Address)

\_\_\_\_\_  
(Printed Name)

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Email and Phone Contact)

**Fire Stop Contractor (if applicable)**

I certify that the information provided in this document is true and accurate.

\_\_\_\_\_  
(Printed Name)

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Company Name)

\_\_\_\_\_  
(Email and Phone Contact)

**DISCLAIMER:** This list is not all-encompassing due to the extensive list of adopted codes. The inspector shall document ALL fire and Life Safety violations and require corrections when any are discovered during an inspection.